

FIRST CLASS MAIL

Handbook 18 (File Ahead of Section 7E)
Temporary Instruction
Western Electric Company, Incorporated
Installation Engineering - Kearny

Section T.I. - 7E
5-19-67
Replaces issue of
2-17-67

CONNECTING-MOUNTING TERMINALS AND STUD CONNECTORS

1. GENERAL

1.1 This T.I. is issued to provide the latest information on the type of finish on bolts, screws, nuts, washers, bus bar supports and clips which may be used in the assembly of bus bar, terminal and stud connectors.

2. INSTRUCTION

2.1 Paragraph 5.2 shall be changed to read:

5.2 Ferrous bolts, screws, nuts, washers, bus bar supports and clips used in fastening aluminum to aluminum, copper to copper, or combinations of metals shall be zinc or cadmium plated plus a chromate treatment. Zinc or cadmium finished parts are standard; however, copper finished parts may be used when furnished.

→ Arrowed lines indicate new or changed information.

Manager, Product Engineering

Printed in U.S.A.