

FIRST CLASS MAIL

Handbook 18 (File Ahead of Section 8B)
Temporary Instruction
Western Electric Company, Inc.
Installation Engineering - Kearny

Section T.I. - 8B
5-19-67

BENDING, CUTTING, DRILLING, SUPPORTING, ERECTING & CONNECTING

1. GENERAL

1.1 This T.I. is issued to provide the latest information on the type of finish on bolts, screws, nuts, washers, bus bar supports and clips which may be used in the assembly of bus bar, terminal and stud connectors.

2. INSTRUCTION

2.1 Paragraph 10.1 shall be changed to read:

10.1 Ferrous bolts, screws, nuts, washers, bus bar supports and clips used in fastening aluminum to aluminum, copper to copper, or combinations of metals shall be zinc or cadmium plated plus a chromate treatment. Zinc or cadmium finished parts are standard; however, copper finished parts may be used when furnished.

Manager, Product Engineering

Printed in U.S.A.