

BIS
Serial # 15
valing

FIRST CLASS MAIL

Installation Engineering Handbook 18 (File Ahead of Section 9A)
Temporary Instruction Section T.I. - 9A
Western Electric Company, Incorporated
Kearny Works 10-28-68

CONDUIT - GENERAL
POWER ROOM AND FRAME AND AISLE LIGHTING
FLUORESCENT LAMPS

1. GENERAL

1.1 Effective January 1, 1969, Fluorescent Lamps used for Frame and Aisle Lighting requirements will no longer be furnished by the Western Job Specification. The "A" Section of the Job Specification will contain a general note as follows:

"The Installer shall request the Telephone Company to furnish _____ F-40 (4 ft.) and/or _____ F20/T-12 (2 ft.) fluorescent lamps required for frame and aisle lighting for the order."

2. INSTRUCTION

2.1 After Paragraph 2.12 add the following:

2.33 All fluorescent lamps shall be furnished by the Telephone Company. The Installer should notify the Telephone Company representative at least two weeks in advance, as to the quantity and size (wattage) of the fluorescent lamps required for the job.

Manager, Product Engineering

Printed in U.S.A.