

URGENT INFORMATION SUPPLEMENT

KS-21501 GAS TURBINE ENGINE ALTERNATOR  
900/750 KW (J-86653)

1. GENERAL

- 1.1 The contract between Western Electric and Solar-Division of International Harvester does include the services of a factory representative during initial start up.

2. INSTRUCTION

- 2.1 Change Paragraph 1.51 to remove the underlined portion. Correct location of coupling. The paragraph will then read as follows;

- 1.51 As part of the contract with Solar, a supplier's representative will be made available during the initial start and test of the unit. When the set is shipped with the coupling disassembled between the gear box and the alternator, critical realignment and torquing will be required when replacing it.

"NOTICE: NOT FOR USE OR DISCLOSURE OUTSIDE THE  
BELL SYSTEM EXCEPT UNDER WRITTEN AGREEMENT"

Printed in U.S.A.

Manager, Product Engineering